

## Nixon, Elizabeth

---

**From:** Michael Intrieri <mintrieri@sundrumsolar.com>  
**Sent:** Friday, February 08, 2013 12:11 PM  
**To:** Nixon, Elizabeth  
**Cc:** george Jalbert  
**Subject:** Thermal Metering Standards

Hello Elizabeth,

We have been monitoring Thermal Energy for a number of years now at SunDrum Solar. The standards we are most comfortable with are Temperature sensors must meet IEC751 and manufacturers tolerance of the flow meter must be +/- 0.5% or better. Would be happy to show you some of the data we are gathering. The Electrical standard for revenue grade we bump into most often is the measure equipment needs to be listed on the California list of approved revenue grade electric meters.

Sincerely  
Michael Intrieri  
SunDrum Solar  
(978) 257-2981